

[01/26/2021]

ADDENDUM NO. #3
City of Troy
Troy Pedestrian Paths

This addendum forms a part of the bidding and contract documents and modifies the bidding documents. Acknowledge receipt of this addendum in space and include it with your bid. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

Details:

Fold down bollard shall be furnished by the contractor. Revise Plan Sheet 34, Bollard Gate Detail to delete the text "SUPPLIED BY MADISON COUNTY TRANSIT".

Plans:

1. REPLACE Sheet, Details Sheet 34

Addendum #3 consists of 1 pages of text and 1 plan sheets.

RETURN ONE SIGNED COPY TOGETHER WITH YOUR PROPOSAL


Addendum No. 3 is hereby acknowledged.

Name of Bidder: _____



By: _____ Title: _____

Address: _____


Telephone: _____ Date: _____



1 BOLLARD GATE DETAIL
SCALE: NO SCALE




2 DETECTABLE WARNING DETAIL
SCALE: NO SCALE




CONTRACTION JOINT

- NOTES:
1. CONTRACTION JOINTS ARE TO BE ON ±5' CENTERS
 2. EXPANSION JOINTS ARE TO BE ON ±100' CENTERS AND AT POINTS OF CURVATURE.
 3. EXPANSION JOINT REQUIRED BETWEEN THE SIDEWALK AND EXISTING PAVEMENT OR STRUCTURES.
 4. ALL EXPANSION JOINTS SHALL BE SEALED WITH GUN GRADE SEALANT.



EXPANSION JOINT

3 EXPANSION & CONTRACTION JOINTS FOR CONCRETE PAVEMENT
SCALE: NO SCALE



4 CROSSING DETAIL
SCALE: NO SCALE

FILE NAME = 19090 - DETAILS.DWG



USER NAME =	SAM WRIGLEY	DESIGNED -	MYS	REVISED -	
PLOT SCALE =	1' = 1'	DRAWN -	BAM	REVISED -	
PLOT DATE =	2020-11-25	CHECKED -	TLC	REVISED -	
		DATE -	20-11-25	REVISED -	

CITY OF TROY
116 E MARKET ST
TROY, IL 62294

SITE DETAILS		
SCALE:	SHEET NO. 2 OF 7 SHEETS	STA. TO STA.

F.A. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
		MADISON	86	34
CITY OF TROY PEDESTRIAN PATHS				
CITY OF TROY				