

This addendum forms a part of the contract documents and modifies the original bidding documents dated June 1, 2022.

Questions and Clarifications:

1. Can insurance requirements be met by using a combination of both primary and excess liability insurance? Meaning an umbrella can be used to cover the differences in general liability, employer's liability, and auto liability? Also, the requirements specifically state that the insurance must be maintained by any subcontractors that the contractor hires. Does this mean that all subcontractors will need to minimally have a \$5,000,000 umbrella?

The insurance section of the project manual has been updated.

2. Do you have a Basis of Design manufacturer/supplier for the floating dock?

There was no basis of design for the floating dock, the fixed dock was based on PermaTrak. As for the floating dock option one recommended option would be:

*Tiger Docks
35 Cooperative Way
Wright City, MO 63390
(636)745-7003*

3. On sheet L4.1 of the plans (1.1 A) states that the dock is to be a floating dock. Per the rep for PermaTrak their system must be a fixed structure and cannot be installed as a floating pier.

The dock can be either floating or fixed, whatever provides the most cost-effective solution from the Contractor.

4. The PermaTrak rep also stated that he could not design the footings for the dock without a Geotech Report. Is there a Geotech report that was done that was not included in the plans? If not, is there a design that we should use for bidding purposes?

A Geotech report was not completed for the project. Designer shall assume poor soils. Contractor should include the cost to complete soil verification testing as part of their bid.

5. Is the depth of the pond at the dock location known?

The depth of the pond is unknown. The review drainage analysis drawings from the original design of the pond by TWM are attached for information purposes only.

Project Manual:

1. **Page 4** – ADD “(to include umbrella insurance policies)” to Section 30-a-iii, of the general terms and conditions of bidding.
2. **Page 5** – REPLACE Section 30-c of the general terms and conditions of bidding with the attached wording.