

**ADDENDUM #1**

This addendum forms a part of the contract documents and modifies the Addendum #1 bidding documents dated May 29, 2025.

**Clarifications:**

1. #5 Smooth bar dowel baskets will be required at all transverse joints. These #5 smooth bar dowel baskets will be included in the cost of PCC PAVEMENT, 8".
2. See detail "TYPE D – TIED TRANSVERSE CONSTRUCTION JOINT" on page C2.3 for further instruction.
3. The completion date of August 15<sup>th</sup>, 2025 is moved back to September 12<sup>th</sup>, 2025.

Addendum #1 consists of:

1 Page - Bid Form

-----  
RETURN ONE SIGNED COPY TOGETHER WITH YOUR PROPOSAL

Addendum No. 1 is hereby acknowledged.

Name of Bidder: \_\_\_\_\_

By: \_\_\_\_\_ Title: \_\_\_\_\_

Address: \_\_\_\_\_

Telephone: \_\_\_\_\_ Date: \_\_\_\_\_